




Legenda:

-  Usina com reservatório
-  Usina a fio d'água
-  Estação fluviométrica

UHE Itaipu Hotel Cataratas

Data	Q diária (m³/s)
10/03/26	617
11/03/26	683
12/03/26	683
13/03/26	913

Atualizado em:
13/03/26 14:00

Salto Caxias

Data	Aflu (m³/s)	Deflu (m³/s)
10/03/26	794	604
11/03/26	709	661
12/03/26	748	748

Salto Osório

Data	Aflu (m³/s)	Deflu (m³/s)
10/03/26	653	736
11/03/26	618	618
12/03/26	679	660

Jordão

Data	V.U. (%)	Aflu (m³/s)	Deflu (m³/s)
10/03/26	22,15	62	10
11/03/26	15,40	24	10
12/03/26	16,59	20	10

Fundão

Data	Aflu (m³/s)	Deflu (m³/s)
10/03/26	47	51
11/03/26	21	21
12/03/26	42	35

Santa Clara

Data	V.U. (%)	Aflu (m³/s)	Deflu (m³/s)
10/03/26	37,06	43	38
11/03/26	37,89	38	13
12/03/26	37,78	37	40

Túnel de derivação

Data	Vazão Transferida (m³/s)
10/03/26	48
11/03/26	34
12/03/26	7

Baixo Iguaçu

Data	Aflu (m³/s)	Deflu (m³/s)
10/03/26	631	491
11/03/26	702	754
12/03/26	789	827

Salto Santiago

Data	V.U. (%)	Aflu (m³/s)	Deflu (m³/s)
10/03/26	42,59	449	733
11/03/26	42,00	371	654
12/03/26	41,37	392	693

Segredo

Data	V.U. (%)	Aflu (m³/s)	Deflu (m³/s)
10/03/26	26,11	272	403
11/03/26	25,12	312	356
12/03/26	25,91	337	302

Foz do Areia


Data	V.U. (%)	Aflu (m³/s)	Deflu (m³/s)
10/03/26	21,72	210	184
11/03/26	21,58	192	253
12/03/26	21,32	184	297

Rio Paraná


Rio Iguaçu

Rio Jordão

Estação Fluviométrica - Hotel Cataratas



● Funcionamento do Parque Nacional do Iguaçu (das 9h às 16h) ● Vazão (m³/s) ■ Vazão mínima para beleza cênica (350 m³/s)



Quebra-Queixo

Data	V.U. (%)	Aflu (m³/s)	Deflu (m³/s)
10/03/26	42,69	30,61	21
11/03/26	50,57	55,26	32
12/03/26	57,31	40,91	21

Campos Novos

Data	V.U. (%)	Aflu (m³/s)	Deflu (m³/s)
10/03/26	24,39	134,97	108
11/03/26	25,00	143,03	134
12/03/26	25,20	136,01	133

Garibaldi

Data	V.U. (%)	Aflu (m³/s)	Deflu (m³/s)
10/03/26	21,55	72	135
11/03/26	20,79	130	136
12/03/26	24,25	162	136

Foz do Chapecó

Data	Aflu (m³/s)	Deflu (m³/s)
10/03	416	425
11/03	518	763
12/03	352	298

Itá

Data	Aflu (m³/s)	Deflu (m³/s)
10/03	360	267
11/03	366	288
12/03	343	203

Machadinho

Data	V.U. (%)	Aflu (m³/s)	Deflu (m³/s)
10/03/26	37,02	219	314
11/03/26	36,11	202	313
12/03/26	35,33	218	313

Passo São João

Data	Aflu (m³/s)	Deflu (m³/s)
10/03/26	112	63
11/03/26	122	90
12/03/26	115	134

Monjolinho

Data	Aflu (m³/s)	Deflu (m³/s)
10/03/26	100,68	67
11/03/26	103,97	135
12/03/26	92,48	74

São José

Data	Aflu (m³/s)	Deflu (m³/s)
10/03/26	94	133
11/03/26	95	134
12/03/26	69	108

Passo Fundo

Data	V.U. (%)	Aflu (m³/s)	Deflu (m³/s)
10/03/2026	64,62	25	96
11/03/2026	64,01	4	104
12/03/2026	63,49	5	90

Barra Grande

Data	V.U.(%)	Aflu (m³/s)	Deflu (m³/s)
10/03/2026	29,35	68	60
11/03/2026	29,35	57	57
12/03/2026	29,35	61	61

Legenda:
 Usina com reservatório
 Usina a fio d'água