

Legenda:

 Usina com reservatório

 Usina a fio d'água

Saiba mais sobre as condições de operação do Sistema Hídrico do Rio Paranapanema

Rosana

Data	Aflu (m³/s)	Deflu (m³/s)
11/01	768	842
12/01	595	743
13/01	688	835
14/01	995	750

Capivara

Data	Aflu (m³/s)	Deflu (m³/s)	V.U. (%)
11/01	628	628	80,46
12/01	552	369	80,74
13/01	416	538	80,56
14/01	578	517	80,65

Canoas I

Data	Aflu (m³/s)	Deflu (m³/s)
11/01	162	152
12/01	165	165
13/01	160	180
14/01	156	143

Canoas II

Data	Aflu (m³/s)	Deflu (m³/s)
11/01	154	159
12/01	169	158
13/01	162	157
14/01	161	158

Ourinhos

Data	Aflu (m³/s)	Deflu (m³/s)
11/01	121	122
12/01	120	119
13/01	126	125
14/01	155	156

Piraju

Data	Aflu (m³/s)	Deflu (m³/s)
11/01	102	102
12/01	100	102
13/01	99	101
14/01	101	101

Taquaruçu

Data	Aflu (m³/s)	Deflu (m³/s)
11/01	654	671
12/01	433	466
13/01	549	704
14/01	587	756

Mauá

Data	Aflu (m³/s)	Deflu (m³/s)	V.U. (%)
11/01	220	249	92,28
12/01	205	215	92,16
13/01	194	338	90,29
14/01	184	318	88,55

Salto Grande



Data	Aflu (m³/s)	Deflu (m³/s)
11/01	152	145
12/01	146	157
13/01	148	147
14/01	180	147

Chavantes

Data	Aflu (m³/s)	Deflu (m³/s)	V.U. (%)
11/01	149	124	59,46
12/01	98	123	59,39
13/01	130	130	59,39
14/01	77	160	59,16

Jurumirim

Data	Aflu (m³/s)	Deflu (m³/s)	V.U. (%)
11/01	94	94	50,36
12/01	94	94	50,36
13/01	48	93	50,24
14/01	49	93	50,12




Faixa de Operação

Normal


Vazão defluente máxima média semanal



Sem restrição

Localização do reservatório



Data	Qnatural mensal (m³/s)	MLT 1931-2023 (m³/s)	% MLT
jan/2024	110	326	34%
fev/2024	120	360	33%
mar/2024	99	305	32%
abr/2024	94	216	44%
mai/2024	67	190	35%
jun/2024	66	202	32%
jul/2024	79	173	46%
ago/2024	60	145	42%
set/2024	42	157	27%
out/2024	90	188	48%
nov/2024	186	183	102%
dez/2024	297	229	130%
jan/2025	187	326	57%







Faixa de Operação

Normal


Vazão defluente máxima média semanal

Sem restrição

Localização do reservatório



Data	Qnatural Mensal (m³/s)	MLT 1931-2023 (m³/s)	% MLT
jan/2024	171	507	34%
fev/2024	212	535	40%
mar/2024	159	446	36%
abr/2024	156	320	49%
mai/2024	108	297	36%
jun/2024	113	318	35%
jul/2024	132	273	48%
ago/2024	98	227	43%
set/2024	76	253	30%
out/2024	144	305	47%
nov/2024	293	287	102%
dez/2024	511	348	147%
jan/2025	258	507	51%





Saiba mais sobre as condições de operação do Sistema Hídrico do Rio Paranapanema

Fonte: ONS e Hidro-Telemetria

Superintendência de Operações e Eventos Críticos
Coordenação de Operação de Reservatórios e Sistemas Hídricos

*Dados consistidos sujeitos a novas revisões




Faixa de Operação

Normal

Vazão defluente máxima média semanal

Sem restrição

Localização do reservatório



Data	Qnatural Mensal (m³/s)	MLT 1931-2023 (m³/s)	% MLT
jan/2024	728	1.512	48%
fev/2024	703	1.555	45%
mar/2024	567	1.294	44%
abr/2024	553	975	57%
mai/2024	381	978	39%
jun/2024	366	1.099	33%
jul/2024	484	967	50%
ago/2024	339	798	43%
set/2024	299	878	34%
out/2024	420	1.108	38%
nov/2024	821	1.028	80%
dez/2024	1.790	1.103	162%
jan/2025	733	1.512	48%

