

Legenda:



Usina com reservatório



Usina a fio d'água

Saiba mais sobre as condições de operação do Sistema Hídrico do Rio Paranapanema

Rosana

Data	Aflu (m³/s)	Deflu (m³/s)
26/01	802	950
27/01	811	1.131
28/01	1.137	1.381
29/01	1.417	1.320

Capivara

Data	Aflu (m³/s)	Deflu (m³/s)	V.U. (%)
26/01	1.124	567	83,90
27/01	1.079	893	84,18
28/01	1.276	1.338	84,09
29/01	882	1.378	83,34

Canoas I

Data	Aflu (m³/s)	Deflu (m³/s)
26/01	231	224
27/01	321	301
28/01	344	361
29/01	356	339

Canoas II

Data	Aflu (m³/s)	Deflu (m³/s)
26/01	231	220
27/01	276	300
28/01	346	327
29/01	312	323

Ourinhos

Data	Aflu (m³/s)	Deflu (m³/s)
26/01	122	123
27/01	243	243
28/01	285	285
29/01	267	263

Piraju

Data	Aflu (m³/s)	Deflu (m³/s)
26/01	252	258
27/01	253	249
28/01	254	256
29/01	255	255

Taquarucu

Data	Aflu (m³/s)	Deflu (m³/s)
26/01	630	630
27/01	899	826
28/01	1.251	1.103
29/01	1.365	1.282

Mauá

Data	Aflu (m³/s)	Deflu (m³/s)	V.U. (%)
26/01	412	479	98,26
27/01	410	429	98,01
28/01	387	406	97,76
29/01	384	365	98,01

Salto Grande



Data	Aflu (m³/s)	Deflu (m³/s)
26/01	190	203
27/01	240	258
28/01	344	317
29/01	359	317

Chavantes

Data	Aflu (m³/s)	Deflu (m³/s)	V.U. (%)
26/01	379	126	64,16
27/01	301	259	64,28
28/01	450	281	64,76
29/01	282	282	64,76

Jurumirim

Data	Aflu (m³/s)	Deflu (m³/s)	V.U. (%)
26/01	193	238	53,05
27/01	194	239	52,92
28/01	239	239	52,92
29/01	328	238	53,17





Faixa de Operação

Normal


Vazão defluente máxima média semanal




Sem restrição

Localização do reservatório



Data	Qnatural mensal (m³/s)	MLT 1931-2023 (m³/s)	% MLT
jan/2024	102	326	31%
fev/2024	120	360	33%
mar/2024	99	305	32%
abr/2024	94	216	44%
mai/2024	67	190	35%
jun/2024	66	202	32%
jul/2024	79	173	46%
ago/2024	60	145	42%
set/2024	42	157	27%
out/2024	90	188	48%
nov/2024	186	183	102%
dez/2024	297	229	130%
jan/2025	231	326	71%







Data	Qnatural Mensal (m³/s)	MLT 1931-2023 (m³/s)	% MLT
jan/2024	175	507	35%
fev/2024	212	535	40%
mar/2024	159	446	36%
abr/2024	156	320	49%
mai/2024	108	297	36%
jun/2024	113	318	35%
jul/2024	132	273	48%
ago/2024	98	227	43%
set/2024	76	253	30%
out/2024	144	305	47%
nov/2024	293	287	102%
dez/2024	511	348	147%
jan/2025	350	507	69%

Saiba mais sobre as condições de operação do Sistema Hídrico do Rio Paranapanema

Fonte: ONS e Hidro-Telemetria

Superintendência de Operações e Eventos Críticos
Coordenação de Operação de Reservatórios e Sistemas Hídricos

*Dados consistidos sujeitos a novas revisões




Faixa de Operação

Normal

Vazão defluente máxima média semanal

Sem restrição

Localização do reservatório



Data	Qnatural Mensal (m³/s)	MLT 1931-2023 (m³/s)	% MLT
jan/2024	621	1.512	41%
fev/2024	703	1.555	45%
mar/2024	567	1.294	44%
abr/2024	553	975	57%
mai/2024	381	978	39%
jun/2024	366	1.099	33%
jul/2024	484	967	50%
ago/2024	339	798	43%
set/2024	299	878	34%
out/2024	420	1.108	38%
nov/2024	821	1.028	80%
dez/2024	1.790	1.103	162%
jan/2025	1.025	1.512	68%

