



aitex[®]
research & innovation center

FIRE BEHAVIOUR

Applicant:

COULISSE B.V.

Vonderweg 48
NL-7468 ENTER
HOLANDA

Is authorized to place the label "Curtains Fire Performance Classification" label according to the 2023AU0720.



CLASSIFICATION OF FIRE BEHAVIOUR: CURTAINS

Nº: 23AU0720



The sample referenced as:

"SCR-3003-3%"

MATERIAL:

Fabric with white covered, with a weight of 443 g/m². Composition 70% PVC - 30% polyester.

Has been tested according to the standards EN 1101:1995+A1:2005 and EN 13772:2011, not cleanable material, according to client. The classification according to standard EN 13773:2003 is:

"CLASS 1"

Date of Issue

8st of November 2023



Date: 08/11/2023 9:38:26

Digitally Signed by: DAVID MARSET GIMENO -

NIF: 21697288P

Celia Dolça
Head of Fire Behaviour lab.