

FIRE BEHAVIOUR

Applicant:

COULISSE B.V.


Vonderweg 48
NL-7468 ENTER
HOLANDA

Is authorized to place the label "Curtains Fire Performance Classification" label according to the 2023AU0721.



CLASSIFICATION OF FIRE BEHAVIOUR: CURTAINS

Nº: 23AU0721



The sample referenced as:

"SCR-3005-5%"

MATERIAL:

Fabric with white covered. Composition: 70% PVC - 30% PES, with a weight of 423 g/m².

Has been tested according to the standards EN 1101:1995+A1:2005 and EN 13772:2011, not cleanable material, according to client. The classification according to standard EN 13773:2003 is:

"CLASS 1"

Date of Issue

14st of November 2023



Date: 14/11/2023 17:28:39

Digitally Signed by: DAVID MARSET GIMENO -

NIF: 21697288P

Celia Dolça
Head of Fire Behaviour lab.